

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 4485-0941:104 Page 1 of 1

CATEGORY: Opening Protection (Firestopping)

LISTEE: Minnesota Mining & Mfg. (3M), 3M Ctr, Bldg. 225-1S-02, St. Paul MN 55144
Contact: *Brandon Cordts (651) 733-5580 Fax (651) 737-2263

DESIGN: Models FIRE BARRIER moldable putty. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation, hourly rating and UL label.

APPROVAL: Listed as 1-hour to 3-hour fire-rated firestopping material when constructed in accordance with UL Fire Resistance Directory.

*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**